GOVERNMENT OF NATIONAL CAPITAL TERRITORY OF DELHI **HEADQUARTERS: DELHI FIRE SERVICE, NEW DELHI-110001**

No. F6/DFS/MS/School/2021/WZ/ 93

Dated: 23/02/2021

To.

The Principal, Venkateshwar Global School, Sec-13, Rohini, Delhi-110085.

Sub: Issue of FSC in r/o Venkateshwar Global School, Sec-13, Rohini, Delhi-85. Sir.

This is in reference to your online mail dated 21.01.2021, on the subject cited above. The premise was inspected by the concern nominated authority of this department on 11.02.2021, in presence of Sh. Raj Singh (Admin In Charge) to ascertain the availability and operability of the fire prevention and fire safety measures. Your request for issue of FSC is rejected under sub rule (4) of Rule 35 of DFS Rules-2010 due to following reason:

- 1. 6.0 mtr width of internal road found obstructed & reduced on two sides.
- 2. Fire check door found removed from staircases.
- 3. Terrace doors are not opening toward terrace.
- 4. Terrace Fire pump with capacity 450 & 180 LPM found provided against the required capacity of 900 LPM.
- 5. Changes in building are observed w.r.t approved building plans by this department as two staircases are not going up to terrace.
- 6. Smoke management system found affected as building changed from natural ventilated to fully AC building and atrium found closed from top.

In this regard as stipulated in sub Rule (5) of Rule 35 of DFS Act-2007 & Rules 2010 you may apply with a fresh application for grant of fire safety certificate under sub-rule (2) on Form "I" and it shall be accompanied with a certificate from the architect and owner or occupier that all the fire prevention and fire safety measures are duly complying with the requirements as communicated under sub-rule (4) above, for further consideration in this regard. The web links for DFS Act-2007/ Rules 2010 & Form "I" are as under:

http://www.delhi.gov.in/wps/wcm/connect/doit_fire/FIRE/Home/Fire+Safety+Acts+and+Rules/http:// www.delhi.gov.in/wps/wcm/connect/doit_fire/FIRE/Home/Forms

Yours faithfully

DIRECTOR

Ph; 011-23414000