

GOVERNMENT OF NATIONAL CAPITAL TERRITORY OF DELHI
HEADQUARTERS: DELHI FIRE SERVICE: NEW DELHI-110001

No: F.6/DFS/MS/School/WZ/2021/ 105

Dated: - 25/2/21

To

The Assistant Engineer (E),
Edu. Sub- Divn M1-1, (N)
PWD, ITI Campus, Pusa,
New Delhi- 110012

Sub.: - Regarding issuance of Fire Safety Certificate in r/o Additional SPS class rooms in Govt. Sarvodaya Kanya Vidyalaya (1617036), Amalvas (Jwalapuri), New Delhi-110041.

Sir,

Please refer to your Letter No. 54(SPS School)/PWD Edu. Sub- Divn M1-1(N)/2020-21/54 dated 28.12.2020, on the subject cited above. In this connection, it is to inform you that the school building have been inspected by the officer concerned of this department in presence of Sh. Mahender Singh, (Estate Officer), on 03.02.2021 to check the fire safety arrangements provided in the building.

During the inspection, it was also observed that the building complex is comprised of two blocks: old block and new block. Old block, comprised of ground plus one upper floor and was issued 'Fire Safety Certificate' by this department vide letter No. F.6/DFS/MS/School/2020/278 dated 16.08.2020. New Block is comprised of ground plus three upper floors, served by two staircases. No fire safety arrangements found provided. However, following fire safety arrangements are required in the new block: -

1. First aid hose reel is required at each floor.
2. Terrace pump capacity 450 lpm is required.
3. Width of door is less than required width 1.20 mts.
4. Exit signage at the places mentioned during the inspection in the new block.
5. 02 nos. Fire extinguishers are required at each 300 sq. meters.
6. Overhead water storage tank capacity 10000 lts is required exclusively for firefighting purpose.

In view of the above, 'Fire Safety Certificate' cannot be granted at this stage. You are requested to rectify the above-mentioned fire safety arrangements under intimation to this department.

Yours faithfully

(ATUL GARG)
DIRECTOR

DELHI FIRE SERVICE

Copy to: -

1. The Principal, Govt. Sarvodaya Kanya Vidyalaya (1617036), Amalvas (Jwalapuri), New Delhi- 110041.
2. The Director of Education, Govt. of NCT of Delhi, Old Secretariat, Delhi.