

GOVERNMENT OF NATIONAL CAPITAL TERRITORY OF DELHI
HEADQUARTERS: DELHI FIRE SERVICE, NEW DELHI-110001

No. F6/DFS/MS/WZ/2021/ 113

Dated: 01/03/2021

To,

The Principal,
Parkash Bharti Public School,
St. Block, Prem Nagar-II, Durga,
Mandir Road near Kirari,
Delhi-110086.

Sub: Issuance of Fire Safety Certificate in r/o Parkash Bharti Public School St. Block, Prem Nagar-II, Durga, Mandir Road near Kirari, Delhi-110086.p

Sir,

Kindly reference to online mail dated 08.02.2021, received in this department on the subject cited above. In this connection it is to inform you that the shortcoming already issued by this department letter of even No. 178 dated 11.03.2020 (Copy enclosed). Therefore, you are advised to submit point-wise compliance of shortcomings issued vide this department letter dated 11.03.2020 for further consideration in this matter.

Yours Faithfully

(Dhrampal Bhardwaj)
Dy.Chief Fire Officer
Tel:-01123412050

OK
01/03/2021

GOVERNMENT OF NATIONAL CAPITAL TERRITORY OF DELHI
HEADQUARTERS: DELHI FIRE SERVICE, NEW DELHI-110001

No. F6/DFS/MS/WZ/2020/ 178

Dated: 11/03/2020

To,

The Principal
Parkash Bharti Public School
St. Block, Prem Nagar-II, Durga,
Mandir Road Near Kirari, Delhi-

Sub: Issuance of Fire Safety Certificate in r/o Parkash Bharti Public School St. Block, Prem Nagar-II, Durga, Mandir Road Near Kirari, Delhi-

Sir,


This is in reference with your letter No. P.B.P.S/2019-20/62 dated 11.12.2019 received in outdoor diary no. O.D 27394 dated 12.12. 2019, on the subject cited above. The premise was inspected by the concern nominated authority of this department in presence of Mr. Sandeep Kumar (Chairman) on 12/02/2020 to verify the compliance of fire prevention and fire safety measures required under the rules. The following shortcomings were observed.

1. Terrace pump of 450 lpm is not auto mode.
2. An overhead water storage tank capacity of 10,000 ltr is found reduced to 4000 ltr.

In this regard as stipulated in sub Rule (1) of Rule 37 of DFS Act-2007 & Rules 2010 you are advised to apply again in Form "J" along with a declaration from owner/occupier on Form "K" as required under Rule 38 that all the fire prevention and fire safety measures provided in the building/premise are in best repairs. The web links for DFS Act-2007/ Rules 2010 & Form "J" & "K" are as under:

http://www.delhi.gov.in/wps/wcm/connect/doi_fire/FIRE/Home/Fire+Safety+Acts+and+Rules/
http://www.delhi.gov.in/wps/wcm/connect/doi_fire/FIRE/Home/Forms

Yours Faithfully


(Dhrampal Bhardwaj)
Dy.Chief Fire Officer
Tel:-01125156707

OLU
MH