

GOVERNMENT OF NATIONAL CAPITAL TERRITORY OF DELHI
HEADQUARTERS: DELHI FIRE SERVICE: NEW DELHI-110001

No. F.6/DFS/MS/SZ/School/2021/ 111

Dated: 01/03/2021

To

The Principal,
Govt. Girls Senior Secondary School,
C-Block, Sangam Vihar,
New Delhi 110080

Sub: Regarding issue of Fire Safety Certificate (FSC) in r/o Govt. Girls Senior Secondary School, C-Block, Sangam Vihar, New Delhi 110080


Sir,

This is in reference to your Gmail dated 09/02/2021 received of this department, on the subject cited above. In this connection, it is to inform you that the above mentioned premise was visited by the officer concerned of this department on 23.02.2021 and observed that the shortcoming intimated vide letter no. F.6/DFS/MS/School/SZ/2020/741 dated 24/11/2020 has yet not been complied. (Copy Enclosed for ready reference).

In view of above, you are again requested to rectify the shortcoming under intimation to this department for further action.

Encl: As above

Yours faithfully,



(Sunil Chawdhary)
Dy. Chief Fire Officer (SZ)
Delhi Fire Service



21/29

**GOVERNMENT OF NATIONAL CAPITAL TERRITORY OF DELHI
HEAD QUARTERS: DELHI FIRE SERVICE NEW DELHI-110001**

No. F.6/DFS/MS/School/SZ/2020/ 741

Dated: 24 / 11 / 2020

To,

The Principal
Govt. Girls Sr.Sec. School
C Block, Sangam Vihar,
New Delhi-110080

Subject: Regarding renewal of Fire safety Certificate in r/o Govt. Girls Senior Secondary School, located at C-Block, Sangam Vihar, New Delhi-110080.


Sir,

This is in reference E-mail dated 16/10/2020 received in this department on the subject cited above. In this connection, it is to inform you that the officer concerned of this department has carried out the inspection on 09/11/2020 in the presence of Mr. Rakan Singh (Vice-Principal). The following shortcomings have been observed:


1. Hose reel nozzels are missing
2. Fire Pump found nonfunctional.
3. Exit signage missing at some places.

Keeping in view of above, Fire Safety Certificate cannot be considered at this stage

Yours faithfully



(Sunil Chawdhary)
Dy. Chief Fire Officer
Delhi Fire Service

olc 

Copy to:-

1. Directorate of Education, South MCD, Civic Centre, Minto Road, New Delhi-110002