

GOVERNMENT OF NATIONAL CAPITAL TERRITORY OF DELHI  
HEADQUARTERS, DELHI FIRE SERVICE, CONNAUGHT PLACE  
NEW DELHI

No. F6/DFS/MS/SZ/2021 / 117

Dated: 02/03/2021

To,

Mrs Kiran Sharma (HOS)  
Govt. Girls Senior Secondary School,  
Bijwasan, Bharthal Road,  
New Delhi – 110077

Subject: Renewal of Fire Safety Certificate iro Govt. Girls Senior Secondary School, Located at Bijwasan, Bharthal Road, New Delhi – 110077.

Sir,


Please refer to your letter no. GGSSS/BIJ/2020-21/396 dated 02/02/2021 on the subject mentioned above. In this connection it is to inform you that the premises was inspected by the officer concerned from this department on 16/02/2021 in presence of Mrs. Kiran Sharma (HOS) for fire safety point of view.

1. The Passage lead to school building is narrowed due to plantations.
2. Fire extinguishers of DCP type 5kg capacity found removed.
3. School activities were noticed in some blocks comprising of ground floor only & No FSC has been issued by this department for that blocks.

You are requested to comply the abovementioned shortcomings under intimation to this department.

In view of the above shortcomings Fire Safety Certificate cannot be considered at this stage.

Yours faithfully,



(Sunil Chaudhary)  
Dy. Chief Fire officer  
Delhi Fire Service

Copy to:-

1. Director of Education, Govt. of NCT of Delhi, Old Secretariat, New Delhi-110054.