

**GOVERNMENT OF NATIONAL CAPITAL TERRITORY OF DELHI  
HEADQUARTERS: DELHI FIRE SERVICE, NEW DELHI-110001**

No. F6/DFS/MS/School/WZ/2021/ 112

Dated: 01/03/2021

To,

The Principal,  
Raja Ram Mohan Roy Public School,  
08, Madhuban Chowk,  
Rohini, Delhi-85

**Sub:** Issue of FSC in r/o Raja Ram Mohan Roy Public School, 08, Madhuban Chowk Rohini, Delhi-85.

Sir,

Kindly reference to online mail dated 11.01.2021, received in this department on the subject cited above. The premise was inspected by the concern nominated authority of this department on 05.02.2021, in presence of Inderjeet Bansal to ascertain the availability and operability of the fire prevention and fire safety measures. Your request for issue of FSC is rejected under sub rule (4) of Rule 35 of DFS Rules-2010 due to following reason:

1. Terrace Fire pump with capacity 450 lpm provided but not functional.

In this regard as stipulated in sub Rule (5) of Rule 35 of DFS Act-2007 & Rules 2010 you may apply with a fresh application for grant of fire safety certificate under sub-rule (2) on Form "I" and it shall be accompanied with a certificate from the architect and owner or occupier that all the fire prevention and fire safety measures are duly complying with the requirements as communicated under sub-rule (4) above, for further consideration in this regard. The web links for DFS Act-2007/ Rules 2010 & Form "I" are as under:

[http://www.delhi.gov.in/wps/wcm/connect/doi\\_t\\_fire/FIRE/Home/Fire+Safety+Acts+and+Rules/](http://www.delhi.gov.in/wps/wcm/connect/doi_t_fire/FIRE/Home/Fire+Safety+Acts+and+Rules/)

[http://www.delhi.gov.in/wps/wcm/connect/doi\\_t\\_fire/FIRE/Home/Forms](http://www.delhi.gov.in/wps/wcm/connect/doi_t_fire/FIRE/Home/Forms)

Yours faithfully

(Dhrampal Bhardwaj)  
Dy.Chief Fire Officer  
Tel:-01123414250

DL  
Ry