

GOVERNMENT OF NATIONAL CAPITAL TERRITORY OF DELHI
HEADQUARTERS: DELHI FIRE SERVICE: NEW DELHI-110001

No. F.6/DFS/MS/SZ/School/2021/ 107

Dated: 01/03/2021

To

The Principal,
SDMC Pratibha Vidyalaya,
C- Block, Sangam Vihar,
New Delhi-110062

Sub: Regarding issue of Fire Safety Certificate (FSC) in r/o SDMC Pratibha Vidyalaya, C-Block, Sangam Vihar, New Delhi - 110062

Sir,

This is in reference to your Gmail dated 05/02/2021 received of this department, on the subject cited above. In this connection, it is to inform you that the above mentioned premise was visited by the officer concerned of this department on 23.02.2021 and observed that the shortcoming intimated vide letter no. F.6/DFS/MS/School/SZ/2016/2185 dated 14/09/2016 has yet not been complied. (Copy Enclosed for ready reference).

In view of above, you are again requested to rectify the shortcoming under intimation to this department for further action.

Encl: As above

Yours faithfully,



(Sunil Chawdhary)
Dy. Chief Fire Officer (SZ)
Delhi Fire Service



GOVERNMENT OF NATIONAL CAPITAL TERRITORY OF DELHI
HEADQUARTERS: DELHI FIRE SERVICE: NEW DELHI- 110001

cl/2

No. E6/DFS/MS/School/SZ/2016/ 2185

Dated: 14/09/16

To

The Principal,
SDMC Pratibha Vidyalaya,
C-Block, Sangam Vihar, New Delhi-62

Sub.: - Regarding Issuance of Fire Safety Certificate in r/o SDMC Pratibha Vidyalaya,
C- Block, Sangam Vihar, New Delhi.

Madam,

This has reference to your letter no. Nil dated 05.08.2016 on the subject cited above. In this connection, it is to inform you that the officer concerned of this department re-inspected the aforesaid school building in your presence on dated 27/08/2016 to verify the compliance of shortcomings communicated vide letter no. F.6/DFS/MS/School/2013/2712 dated 24/012/2013 and observed as below: -

1. The school building is not accessible to the fire engine.
2. Fire extinguishers provided are insufficient, 4 more to be provided.

In view of the above shortcoming, Fire Safety Certificate cannot be at this stage. You are requested to rectify the shortcoming under intimation to this department for further action in the matter.

Yours faithfully,

VK
13/9.
Vipin Kental
Chief Fire Officer
Delhi Fire Service
Ph.: 011-23412225

fen

Copy to: -

1. The Director of Education,
Govt. of NCT of Delhi,
Old Secretariat, New Delhi