

GOVERNMENT OF NATIONAL CAPITAL TERRITORY OF DELHI
HEAD QUARTERS, DELHI FIRE SERVICE, NEW DELHI -110001

No.F6/DFS/MS/NDZ/2021/ 120

Dated:- 02/03/2021

To

The Vice-Principal,
Govt. Co-Ed. Sr. Sec. School,
Chilla Village, Mayur Vihar,
Ph-I, Delhi – 110091.

Sub:- Regarding renewal of FSC in r/o Govt. Co-Ed. Sr. Sec. School, Chilla Village, Mayur Vihar,
Ph-I, Delhi – 110091.

Sir,

This has reference to your letter No. G (Co-ed) SSS/CV/2021/83 dated 17/02/2021 on the subject cited above. In this regard, it is to inform you that the shortcomings already communicated by this department vide letter No. F6/DFS/MS/NDZ/2020/761 dated 09/12/2020 (photocopy enclosed) has not been rectified.

Hence, the Fire Safety Certificate cannot be considered at this stage. You are requested to rectify the shortcomings under the intimation to this department for further necessary action in this regard.

Yours faithfully


13/21

(Dr. S.K. Tomar)
Dy. Chief Fire Officer

Copy to:-

The Joint Director of Education,
(Land & Estate),
Directorate of Education, Lucknow Road, Delhi -54.



c/31

GOVERNMENT OF NATIONAL CAPITAL TERRITORY OF DELHI
HEAD QUARTERS : DELHI FIRE SERVICE : NEW DELHI – 110001

No.F6/DFS/MS/NDZ/2020/ 761

Dated:- 09/12/2020

To

The Vice-Principal,
Govt. Co-Ed. Sr. Sec. School,
Chilla Village, Mayur Vihar,
Ph-I, Delhi – 110091.

Sub:- Regarding renewal of FSC in r/o Govt. Co-Ed. Sr. Sec. School, Chilla Village, Mayur Vihar,
Ph-I, Delhi – 110091.

Sir,

This has reference to your letter No. G (Co-ed) SSS/CV/2020/537 dated 25/11/2020 on the subject cited above. In this regard, it is to inform you that the premises was inspected by the officer concerned of this department on 02/12/2020 in the presence of Mrs. Anita (Vice-Principal) & Mr. K.D. Tiwari (Estate Manager) and the following shortcomings were observed:-

1. One staircases of 1.5 meter demolished due to new construction hence travel distance is not meeting.

Hence Fire Safety Certificate can not be considered at this stage.

Yours faithfully


8/12/2020

(Dr. S.K. Tomar)
Dy. Chief Fire Officer

Copy to:-

The Joint Director of Education,
(Land & Estate),
Directorate of Education, Lucknow Road, Delhi -54.

