

**GOVERNMENT OF NATIONAL CAPITAL TERRITORY OF DELHI  
HEADQUARTERS: DELHI FIRE SERVICE: NEW DELHI- 110001**

No. F.6/DFS/MS/School/2021/ 115

Dated: 01/03/2021

To,

The Principal,  
Lovely Rose Public Secondary School,  
C-9, Yamuna Vihar, Delhi-110053

**Sub:- Regarding renewal of Fire Safety Certificate .**

Sir,

With reference to your letter No. LRPS/1448 dated 08/2/2021 on the subject cited above; it is informed that officer concerned of this department inspected the school to check fire prevention and fire safety measures in presence of Mr. Manoj (representative of the school) on dated 19/02/2021. During the course of inspection following observations were made:-

1. Jockey pump of discharge capacity 180 LPM discharge at 40 meters head found removed at the time of inspection.
2. Firefighting system which has been provided in the building was not functional at the time of inspection.
3. Manually operated fire alarm system (MOEFA) was not functional at the time of inspection
4. Exits shall be free from any obstruction / impediments at all the time and should not pass through occupied area, so class room/music room to be shifted accordingly at both floors.
5. Exit Signs are required to be provided in the school building at all exits.

In view of the above, the school building cannot be considered for issuance of Fire Safety Certificate at this stage. Therefore, you are requested to provide the above mentioned fire safety arrangements under intimation to this office for further course of action.

Yours Faithfully,

  
26/2/21

(Dr. S. K. Tomar)  
Dy. Chief Fire Officer

Copy to:-

The Dy. Director of Education,  
B-Block, Yamuna Vihar,  
Delhi-110053

o/c 