

GOVERNMENT OF NATIONAL CAPITAL TERRITORY OF DELHI
HEADQUARTERS: DELHI FIRE SERVICE: NEW DELHI- 110001

No.F6/DFS/MS/School/NDZ/2021 / 118

Dated: 02/03/2021

To,

The Principal,
M.C. Primary Co-Ed School,
Haveli Azam Khan, Chitli Qabar,
Jama Masjid, Delhi

Subject:-Regarding issuance of Fire Safety Certificate in r/o M.C. Primary Co-Ed School, Haveli Azam Khan, Chitli Qabar, Jama Masjid Delhi.

Sir,

With reference to Email dated 12.02.2021 on the subject cited above. It is informed that the School building was inspected by the Assistant Divisional Officer (SPM) from this department on 16.12.2021 in the presence of Mr. Uzma Tasleem (Incharge), and it was observed that the building comprised of ground + 02 upper floors. The following shortcomings were observed during the inspection.

1. School is not accessible to fire engines as approach road width is less than 6 meters.
2. An additional staircase is required having width not less than 0.75 m.

In view of the above shortcomings, the issuance of Fire Safety Certificate cannot be considered at this stage.

Yours faithfully,


25/2/21

(Dr. S.K. Tomar)

Dy. Chief Fire Officer

Tel: 011-23412025


25/2

Copy to:-

The Directorate of Education,
North Delhi Municipal Corporation, City S.P. Zone, Old Hindu College, Kashmiri Gate, Delhi