

**GOVERNMENT OF NATIONAL CAPITAL TERRITORY OF DELHI  
HEADQUARTERS: DELHI FIRE SERVICE, NEW DELHI-110001**

No: F.6/DFS/MS/School/2021/SZ /128

Dated: 04/03/2021

To,

The Principal,  
Mata Kasturi Devi Sr. Sec. Public School,  
Gopal Nagar, Najafgarh, New Delhi-110043.

Sub: - Regarding renewal of Fire Safety Certificate in r/o Mata Kasturi Devi Sr. Sec. Public School, Gopal Nagar, Najafgarh, New Delhi-110043.

Sir/Madam,

This has reference to your Letter No. Nil dated 23/02/2021 on the subject cited above. In this connection, it is to inform you that the inspection of above said school building has been carried out by officer concerned of this department on 19/02/2021 in presence of Sh. Kulbhushan Singh (Manager).


During the course of inspection it was observed that school building comprised of ground floor plus two upper floors was issued FSC by this department vide letter no. F.6/DFS/MS/School/2016/SZ/992 dated 09.06.2016.

The following shortcomings were observed:-

1. An additional staircase having width of 1.0 m provided in place of required 1.35 m from ground floor to terrace.

You are advised to rectify the above-mentioned shortcomings for taking further action as necessary for grant of Fire Safety Certificate.

Yours Faithfully,



(Sunil Chawdhary)

Dy. Chief Fire Officer

Copy to:-

Director of Education,  
Govt. of NCT of Delhi, Old Secretariat,  
New Delhi – 110054

