

GOVERNMENT OF NATIONAL CAPITAL TERRITORY OF DELHI
HEADQUARTERS, DELHI FIRE SERVICE, CONNAUGHT PLACE
NEW DELHI

No. F6/DFS/MS/SZ/2021/123

Dated: 03/03/2021

To,

The Principal,
St. Gregorios School,
Sector-11, Dwarka,
New Delhi-110075.

Subject: Renewal of Fire Safety Certificate iro St. Gregorios School, Located at, Sector-11, Dwarka, New Delhi-110075.

Sir,

Please refer to your letter no./ Email Dated 12/02/2021 on the subject mentioned above. In this connection it is to inform you that the premises was inspected by the officer concerned from this department on 22/02/2021 in presence of Sh. M.Boyaz (Principal) for fire safety point of view.

1. The internal road has been narrowed due to planters.
2. The widths of staircases are than 1.5m.
3. The width of MP Hall doors are less than 2m.
4. Fire check door found not provided at lift logy & staircases.
5. Public Address System found not provided.
6. Internal hydrant found not functional.
7. Yard hydrants found not provided.
8. Pressurization of Lift Shaft found not provided.
9. Lift Signage found not provided.
10. Fire control room found not provided.
11. Overhead fire water tanks inspection ladder is not provided

You are requested to comply the abovementioned shortcomings under intimation to this department.

In view of the above shortcomings Fire Safety Certificate cannot be considered at this stage.

Yours faithfully,


(Atul Garg)
Director
Delhi Fire Service

Copy to:-

1. Directorate of Education Old Secretariat Delhi – 110054