

GOVERNMENT OF NATIONAL CAPITAL TERRITORY OF DELHI
HEAD QUARTERS : DELHI FIRE SERVICE : NEW DELHI – 110001

No.F6/DFS/MS/School/2021/ 129

Dated: 04 /03/2021

To

The Principal,
EDMC Primary School,
A-3, Mayur Vihar, Ph-III, Delhi-96.

Sub: Regarding Renewal of FSC in r/o EDMC Primary School located at A-3, Mayur Vihar, Ph-III, Delhi-96.

Sir,

This has reference to email dated 08/02/2021 on the subject cited above. In this regard, it is to inform you that the site was inspected by the officer concerned of this department on 01/03/2021 in the presence of Mr. A.S. Sharma (Principal) and the following shortcomings were observed:-

1. Earlier block was G + 01 upper floor, now one more floor added, hence building is G + 02 upper floors and no fire fighting system is provided as per NBC.

Hence, renewal of Fire Safety Certificate can not be considered at this stage.

Yours faithfully



(Dr. S.K. Tomar)
Dy. Chief Fire Officer
Delhi Fire Service



Copy to:-

The Director (Education),
Govt. of NCT, Old Sectt.
Delhi - 54.