

GOVERNMENT OF NATIONAL CAPITAL TERRITORY OF DELHI
HEAD QUARTERS : DELHI FIRE SERVICE : NEW DELHI – 110001

No.F6/DFS/MS/School/2021/ 130

Dated: 04/03/2021

To

The Principal,
Salwan Public School,
Mayur Vihar Ph-III, Delhi-96.

Sub: Regarding Renewal of FSC in r/o Salwan Public School located at Mayur Vihar Ph-III, Delhi-110096.

Sir,

This has reference to email dated 20/02/2021 on the subject cited above. In this regard, it is to inform you that the site was inspected by the officer concerned of this department on 01/03/2021 in the presence of Mrs. Monika (PGT, Eco.) and the following shortcomings were observed :-

1. Hose reel/hydrant not provided at terrace.
2. One hall found constructed and in use at 4th floor, the sanction plan of 4th floor to be submitted.

Hence, renewal of Fire Safety Certificate can not be considered at this stage.

Yours faithfully


413121

(Dr. S.K. Tomar)
Dy. Chief Fire Officer
Delhi Fire Service

Copy to:-

The Director (Education),
Govt. of NCT, Old Sectt.
Delhi - 54.

