

**GOVERNMENT OF NATIONAL CAPITAL TERRITORY OF DELHI
HEADQUARTERS: DELHI FIRE SERVICE: NEW DELHI- 110001**

No.F6/DFS/MS/School/2021/ 136

Dated: 10/03/2021

To,

The Principal,
Crescent School,
Jamaloo Ka Bagh
Road No.66, Maujpur,
Delhi-110032

Subject:- Request to renew No Objection Certificate for Fire Safety.


Sir,

With reference to your on-line letter dated 02/02/2021 on the subject cited above, it is informed that officer concerned of this department inspected the school from fire safety point of view in presence of Ms. Zatoon Nisah Principal, of the School on dated 19/02/2021. The School building comprises of basement, ground plus three upper floors (Third Floor has been sealed by MCD, School is running upto two floor only). During the course of inspection following observations were made:-

1. Staircase to terrace(blocked and locked) was not accessible at the time of inspection.
2. The fire pump was not accessible at the time of inspection.
3. Overhead Tank for firefighting was not accessible at the time of inspection.

In view of the above, the school building cannot be considered for issuance of Fire Safety Certificate at this stage. Therefore, you are requested to provide the above mentioned fire safety arrangements under intimation to this office for further course of action.

Yours Faithfully,



(Dr. S. K. Tomar)
Dy. Chief Fire Officer

Copy to:-

The Joint Director of Education (Land & Estate),
Directorate of Education,
Lucknow Road, Delhi-54