

9/12

**GOVERNMENT OF NATIONAL CAPITAL TERRITORY OF DELHI
HEADQUARTERS: DELHI FIRE SERVICE: NEW DELHI- 110001**

No.F6/DFS/MS/School/2021/ 134

Dated: 10/03/2021

To,
The Principal,
E.D.M.C. Primary School,
Jwala Nagar, Shahdara,
Delhi-110032

Sub:- Regarding issuance of Fire Safety Certificate.

Sir,

With reference to Email ID-hos1051186@gmail.com dated 16/02/2021 on the subject cited above, it is informed that officer concerned of this department inspected the school from fire safety point of view in presence of Ms. Santosh Gupta, Principal of the School on dated 26/02/2021. The School building comprises of ground plus two upper floors. During the course of inspection following observation was made:-

1. A fire pump with 450 liters per minutes discharge at 40 meters head (4kgf/sq.cm.) is required to be provided.
2. Hose reel provided but not functional at the time of inspection.

In view of the above, the school building cannot be considered for issuance of Fire Safety Certificate at this stage. Therefore, you are requested to provide the above mentioned fire safety arrangements under intimation to this office for further course of action.

Yours Faithfully,



(Dr. S.K. Tomar)
Dy. Chief Fire Officer



Copy to:-

The Director of Education, EDMC
Udyog Sadan, Plot No. 419, FIE,
Patparganj, Delhi -92