

Chb

GOVERNMENT OF NATIONAL CAPITAL TERRITORY OF DELHI
HEADQUARTERS: DELHI FIRE SERVICE: NEW DELHI- 110001

No.F6/DFS/MS/School/2021/ 135

Dated: 10/03/2021

To,
The Principal,
EDMC Primary School,
Ram Nagar Extn., Mandoli Shahdara,
Delhi-110032.

Sub:- Regarding issuance of Fire Safety Certificate.

Sir,
With reference to your letter No. Nil dated 02/02/2021 and Letter No.F6/DFS/MS/School/2017/1120 dated 02/05/2017 issued by this department on the subject cited above, it is informed that officer concerned of this department inspected the school from fire safety point of view on dated 22/02/2021. During the course of inspection following observation were made:-

1. Staircase of width 1.50 meter failing which an additional staircase of 0.75 meter width is required to be provided in the school building.
2. A fire pump with 450 liters per minute discharge at 40 meters head (4kgf/sq.cm.) is required to be provided at terrace level to feed firefighting system.
3. An overhead water tank having 10,000 liters capacity is required to be provided exclusively for firefighting systems.
4. Hose reels which has been provided in the building, were not functional at the time of inspection.
5. Exit Signs are required to be provided in the school building at all exits.

In view of the above, the school building cannot be considered for issuance of Fire Safety Certificate at this stage. Therefore, you are requested to provide the above mentioned fire safety arrangements under intimation to this office for further course of action.

Yours Faithfully,



(Dr. S. K. Tomar)
Dy. Chief Fire Officer



Copy to:-

The Director of Education, EDMC
Udyog Sadan, Plot No.419,FIE,
Patparganj, Delhi 110092