

**GOVERNMENT OF NATIONAL CAPITAL TERRITORY OF DELHI**  
**HEADQUARTERS: DELHI FIRE SERVICE: CONNAUGHT PLACE:**  
**NEW DELHI – 110001**

No.F6/DFS/MS/School/MN/2021 / 132

Dated: 08/03/2021

To

The Principal,  
Shri Guru Harkrishan Model School,  
D- Block, Tagore Garden Extn, New delhi-110027.

Sub: - Inspection report in r/o of Shri Guru Harkrishan Model School, D- Block, Tagore Garden Extn, New delhi-110027.


Sir,

Please refer to your Email dated 02.02.2021 on the subject cited above. In this connection it is informed that the premise was re-inspected by the officer concerned of this department on 15.02.2021 in the presence of Sh. Jai Prakash (Principal) to check the workability of existing Fire safety arrangements. During inspection, it has been observed that the said building is comprised of Ground plus two upper floors. Ground & upper floors are served by two staircases, Fire Safety arrangements such as Fire Extinguishers, First Aid Hose reels, terrace pump, Overhead water storage tank & Exit signage are provided. However the following shortcomings were observed:-


1. First Aid Hose reels is found leakage.
2. Fire pump is not found on auto mode.

You are requested to comply the above mentioned shortcoming under intimation to this department for further necessary action.

Yours Faithfully

  
(Dharampal Bhardwaj)  
Dy. Chief Fire officer  
Delhi Fire service

Copy to: - The directorate of Education, old secretariat, Delhi.

o/c   
04/03/2021