

GOVERNMENT OF NATIONAL CAPITAL TERRITORY OF DELHI
HEADQUARTERS: DELHI FIRE SERVICE, NEW DELHI-110001

No. F6/DFS/MS/SCHOOL/MN/138

Dated: 12/03/2021

To

The Principal,
Guru Nanak Public School,
West Avenue, Punjabi Bagh,
New Delhi - 110026

Sub: - Inspection report in respect of Guru Nanak Public School, Punjabi Bagh, New Delhi - 110026.

Sir,

Please refer to your Email dated 14/01/2021 on the subject cited above. In this connection it is informed that the premise was inspected by the officer concerned of this department on 26/02/2021 in the presence of Sh. Durga Prasad (Care Taker) to check the workability of existing Fire safety arrangements. During inspection, it has been observed that the said building is comprised of Ground plus Three upper floors (New Building), Ground plus two upper floors (Old Building) & Ground plus one upper floor (office Block). All are inter connected served by four staircases. Fire Safety arrangements such as Fire Extinguishers, First Aid Hose reels, terrace pump, Overhead water storage tank & Exit signage are provided. However the following shortcomings were observed:-

1. One staircase (Iron) found blocked.
2. First Aid Hose reels are found leakage and non functional.
3. Fire pump is not found on auto mode.
4. Exit signage found removed.
5. Overhead water storage tank 10,000 ltrs capacity is not provided.

You are requested to comply the above mentioned shortcomings under intimation to this department for further necessary action.

Yours faithfully

(Dharampal Bhardwaj)
Dy. Chief Fire Officer
Delhi Fire Service

o/c
10/03/2021
09/03/2021

Copy to: - The directorate of Education, old secretariat, Delhi.