

**GOVERNMENT OF NATIONAL CAPITAL TERRITORY OF DELHI  
HEADQUARTERS: DELHI FIRE SERVICE, NEW DELHI-110001**

No. F6/DFS/MS/School/WZ/2021/ 143  
To,

Dated: 12/03/2021

The Principal,  
M.R. Public School,  
Rajeev Nagar Ext., Barwala road,  
Begum Pur,  
Delhi-110086.

**Sub:** Issue of FSC in r/o M.R. Public School, Rajeev Nagar Ext., Barwala road, Begum Pur, Delhi-110086.

Sir,

Kindly reference to online mail dated 23.12.2020, received in this department on the subject cited above. The premise was inspected by the concern nominated authority of this department in presence of Sh. Lokesh Kumar (Manager) on 28.01.2021 to verify the compliance of fire prevention and fire safety measures required under the rules. The renewal of FSC is rejected under sub rule (3) of Rule 37, in the view of reasons mentioned below:

1. The width of staircase is 1.15 mtr. against the required width of three staircases of 1.5 mtr.
2. 2500 ltrs Over Head water captive tank provided against the required capacity of 10,000 ltrs.

In this regard as stipulated in sub Rule (1) of Rule 37 of DFS Act-2007 & Rules 2010 you are advised to apply again in Form "J" along with a declaration from owner/occupier on Form "K" as required under Rule 38 that all the fire prevention and fire safety measures provided in the building/premise are in best repairs. The web links for DFS Act-2007/ Rules 2010 & Form "J" & "K" are as under:

[http://www.delhi.gov.in/wps/wcm/connect/doi\\_t\\_fire/FIRE/Home/Fire+Safety+Acts+and+Rules/](http://www.delhi.gov.in/wps/wcm/connect/doi_t_fire/FIRE/Home/Fire+Safety+Acts+and+Rules/)

[http://www.delhi.gov.in/wps/wcm/connect/doi\\_t\\_fire/FIRE/Home/Forms](http://www.delhi.gov.in/wps/wcm/connect/doi_t_fire/FIRE/Home/Forms)

Yours Faithfully

  
(Anil Garg)  
DIRECTOR

Ph: 011-23414000

