

C-80

**GOVERNMENT OF NATIONAL CAPITAL TERRITORY OF DELHI
HEADQUARTERS: DELHI FIRE SERVICE: NEW DELHI- 110001**

No. F.6/DFS/MS/School/2021/SZ/ 141

Dated: 12/03/2021

To

The Principal,
Modern School,
Poorvi Marg, Vasant Vihar,
New Delhi - 110057

Sub.:- Renewal of Fire Safety Certificate in r/o Modern School, Poorvi Marg, Vasant Vihar, New Delhi - 110057


Sir,

This has reference to your Gmail dated 23/02/2021 on the subject cited above. In this connection, the said school premises have been inspected by concerned nominated of this department on 03/03/2021 in the presence of Ms Meenakshi (Principal). During the inspection it was observed that school is comprised of Basement plus three upper floors (1st block), Ground floor (Auditorium Hall), Ground plus two upper floors (2nd blocks) all blocks are interconnected. The shortcomings observed are as below.

1. Automatic fire detection and alarming system not working.
2. MOEFA not working in auditorium.
3. Overhead tank capacity 5000 ltrs provided in each block against the required capacity of 10,000 ltrs in each blocks.

In view of above shortcomings, renewal of Fire Safety Certificate cannot be considered at this stage. You are requested to rectify the shortcoming under intimation to this department for further action in the matter.

Yours faithfully,



(Sunil Chawdhary)
Dy. Chief Fire Officer (SZ)
Delhi Fire Service

Copy to: -



1. Directorate of Education, Govt. of NCT of Delhi, Old Secretariat, New Delhi-110054