

GOVERNMENT OF NATIONAL CAPITAL TERRITORY OF DELHI
HEADQUARTERS: DELHI FIRE SERVICE: NEW DELHI-110001

No. F.6/DFS/MS/School/2021/SZ/ 142
To

Dated: 12/03/2021

The Principal,
SDMC Primary (Boys) School,
Tughlakabad Village, New Delhi- 110044.


Sub: Regarding issue of Fire Safety Certificate (FSC) in r/o SDMC Primary, (Boys) School,
Tughlakabad, Village, New Delhi 110044.

Sir,

This is in reference to your letter no nil dated 08/02/2021 on the subject cited above. In this connection, it is to inform you that the above mentioned premise was visited by the officer concerned of this department and observed that the shortcoming intimated vide letter no. F.6/DFS/MS/School/2018/SZ/1937 dated 10/05/2018 has yet not been complied. (Copy Enclosed for ready reference).

Encl: As above

Yours faithfully,



(Sunil Chawdhary)
Dy. Chief Fire Officer (SZ)
Delhi Fire Service



420

GOVERNMENT OF NATIONAL CAPITAL TERRITORY OF DELHI
HEADQUARTERS: DELHI FIRE SERVICE: CONNAUGHT PLACE
NEW DELHI- 110001

Fax No. 011-23412593, Ph. 011-23412225

Dated:16/05/18

No. F.6/DFS/MS/School/2018/SZ/ 1937

To

The Principal,
SDMC Primary (Boy's) School,
Tughlakabad Village, New Delhi-110044

Sub.:- Reg. Issuance of FSC in r/o SDMC Primary (Boy's) School, Tughlakabad Village,
New Delhi-110044

Sir,


This is in reference with your letter No. Nil Dated 06-02-2018 received through outdoor diary No. 2003 dated 08/06/2018 on the subject cited above. In this connection, the school premise was re-visited by officer concern of this department on 12/04/2018 to verify the shortcoming given by the department vide letter no F6/DFS/MS/School/2015/2574 dated 11/12/2015 have not been rectified yet.

During the inspection, the shortcomings observed are as below: -

1. One more staircase required in B block with the width of 0.75 mtrs.
2. Hose-reels found non-functional.
3. Terrace level pump found non-functional.
4. Overhead tank found empty.

In view of above shortcomings, issuance of FSC cannot be considered at this stage. You are requested to rectify the shortcoming under intimation to this department for further consideration in the matter.

Yours faithfully,


(Vipin Kental)
Chief Fire Officer

Copy to: -

1. The Director of Education, Govt. of NCT of Delhi, Old Secretariat, New Delhi.