

**GOVERNMENT OF NATIONAL CAPITAL TERRITORY OF DELHI  
HEADQUARTERS: DELHI FIRE SERVICE: CONNAUGHT PLACE  
NEW DELHI- 110001**

No. F.6/DFS/MS/School/2021/SZ/ 139

Dated: 12/03/2021

To

The HOS / Vice Principal,  
S.D.M.C Primary School,  
Mandi Village  
New Delhi -110047

Sub: Reg. renewal of Fire Safety Certificate in r/o S.D.M.C Primary School, Mandi Village New Delhi -110047

Sir,

This is in reference with your Gmail Dated 24/02/2021 on the subject cited above. In this regard, school premises have been inspected by officer concerned of this department on dated 25.02.2021 in presence of Mr. Indraj Singh to verify the status of existing fire prevention and fire safety measures. During the course of inspection, the shortcomings observed are as below;

1. Only one staircase provided in each blocks against the required two nos of staircase with width of 1.50 mtr each.
2. All Doors size having width of 90 cm against the required width of 1 mtr.

In view of above shortcomings, renewal of Fire Safety Certificate cannot be considered at this stage. You are requested to rectify the shortcoming under intimation to this department for further action in the matter.

Yours faithfully,

**(Sunil Chawdhary)  
Dy. Chief Fire Officer (SZ)  
Delhi Fire Service**

Copy to: -

1. The Director of Education, Govt. of NCT of Delhi, Old Secretariat