

GOVERNMENT OF NATIONAL CAPITAL TERRITORY OF DELHI
HEADQUARTERS: DELHI FIRE SERVICE: NEW DELHI – 110001

No.F6/DFS/MS/WZ/2021/149

Dated: - 18/03/2021

To,

The Principal,
Municipal Corporation, Co-ed., School,
Swan Park, Ashok Vihar, Delhi-110052

Subj:- Issuance of Fire Safety Certificate in respect of Municipal Corporation, Primary, Co-ed., School, Swan Park, Ashok Vihar, Delhi-110052.

Sir,


This has reference to you Email dated 01.03.2021 on the subject cited above. In this connection it is to inform you that the above said building was inspected by the officer concerned of this department from Fire safety point of view on 04.03.2021 in presence of Sh. Bola Nath (Security Incharged), to check the compliance of shortcomings already issued by this department vide letter no. F6/DFS/MS/School/2014/544 dated 06.03.2014 and further vide letter no. F6/DFS/MS/School/2015/394 dated 24.02.2015

During the course of inspection the following shortcomings have been observed:

1. First Aid Hose Reels is provided but found damaged.
2. A Terrace Pump 450 lpm capacity is not provided.
3. Over Head Water storage tank 10,000 ltrs capacity exclusive for firefighting is not provided.
4. Exit signage not provided at some prominent places.

In view of the above shortcomings, fire safety certificate cannot be granted at this stage. You are advised to the direct the applicant to rectify the above mentioned shortcomings under intimation to this department for taking further necessary action.

Yours faithfully,


(Atul Garg)
Director

Copy to:-

1. The Director, Directorate of Education Old Secretariat Delhi – 110054.