

**GOVERNMENT OF NATIONAL CAPITAL TERRITORY OF DELHI
HEADQUARTERS: DELHI FIRE SERVICE: NEW DELHI- 110001**

No. F.6/DFS/MS/School/2021/SZ/ 150

Dated: 18/03/2021

To

The Principal,
Poorna Prajna Public School,
Sector – D, Pocket – 3,
Vasant Kunj, New Delhi - 110070

Sub.:- Renewal of Fire Safety Certificate in r/o Poorna Prajna Public School, Sector – D, Pocket – 3,
Vasant Kunj, New Delhi – 110070.

Sir,

This has reference to your Gmail dated 23/02/2021 on the subject cited above. In this connection, the said school premises have been inspected by concerned nominated of this department on 03/03/2021 in the presence of Sh. Narayan Kulkarni (Admn Officer). During the inspection it was observed that school is comprised of Basement plus three upper floors. The shortcomings observed are as below.

1. First Aid Hose Reels are not working.
2. Terrace level pump capacity 450 LPM provided not working.
3. Overhead tank capacity 10,000 ltrs found empty.
4. Exit signage found removed.

In view of above shortcomings, renewal of Fire Safety Certificate cannot be considered at this stage. You are requested to rectify the shortcoming under intimation to this department for further action in the matter.

Yours faithfully,



(Sunil Chawdhary)
Dy. Chief Fire Officer (SZ)
Delhi Fire Service

Copy to: -

1. Directorate of Education, Govt. of NCT of Delhi, Old Secretariat, New Delhi-110054