

**GOVERNMENT OF NATIONAL CAPITAL TERRITORY OF DELHI
HEADQUARTERS: DELHI FIRE SERVICE: CONNAUGHT PLACE
NEW DELHI- 110001**

No. F.6/DFS/MS/School/2021/SZ/ 146

Dated: 18/03/2021

To

The Principal,
S.D.M.C Co-Ed Primary School,
Indian Airlines Colony,
Vasant Vihar, New Delhi -110057

Sub: Reg. renewal of Fire Safety Certificate in r/o S.D.M.C Co-Ed Primary School, Indian Airlines Colony, Vasant Vihar, New Delhi -110057.


Sir,

This is in reference with your letter no D/265 Dated 10/02/2021 on the subject cited above. In this regard, school premises have been inspected by officer concerned of this department on dated 03/03/2021 in presence of Mr. Ved prakesh Kataria (Principal) to verify the status of existing fire prevention and fire safety measures. During the course of inspection, the shortcomings observed are as below;

1. Width of staircases provided found 1.27 m & 1.12 m against requirement of one staircase of 1.50 m width.

In view of above shortcomings, renewal of Fire Safety Certificate cannot be considered at this stage. You are requested to rectify the shortcoming under intimation to this department for further action in the matter.

Yours faithfully,



(Sunil Chawdhary)
Dy. Chief Fire Officer (SZ)
Delhi Fire Service

