

c-50

GOVERNMENT OF NATIONAL CAPITAL TERRITORY OF DELHI
HEAD QUARTERS: DELHI FIRE SERVICE NEW DELHI-110001

No. No.F6/DFS/MS/School/SZ/2021/ 154

Dated: 23/03/2021

To,

The Principal,
Guru Harkrishan Public School,
Tilak Nagar, New Delhi-110018.

Subject:-Regarding issue of "Fire Safety Certificate" from fire safety point of view in r/o Guru Harkrishan Public School, Tilak Nagar, New Delhi-110018.


Sir,

This is in reference to your letter No- GHPS/TN/2020-21/GEN/4199 Dated -19/02/2021 on the subject cited above. In this connection, it is to inform you that the officer concerned of this department has carried out the inspection of the above-mentioned school from fire safety point of view in presence of Sh. Karamjeet Singh on 08/03/2021. During the course of inspection, the following points / shortcomings were noticed in the school building comprised of basement, ground plus two upper floors.

1. First aid hose reel provided but not functional.
2. A fire pump having 450 LPM provided but not functional.
3. Exit signage's are not provided.


In view of above, the school building can not be considered for grant of fire safety certificate at this stage. Therefore you are requested to rectify the above mentioned shortcomings under the intimation to this department for further course of action.

Yours faithfully



(Sunil Chawdhary)

Dy. Chief Fire Officer
Delhi Fire Services



Copy to:-

1. The Principal, Guru Harkrishan Public School, Tilak Nagar, New Delhi-110018.
2. Director of Education, GNCT of NCT of Delhi, Old Secretariat, Delhi-110054.