

**GOVERNMENT OF NATIONAL CAPITAL TERRITORY OF DELHI**  
**HEADQUARTERS: DELHI FIRE SERVICE: NEW DELHI-110001**

No: F.6/DFS/MS/School/SZ/2021/ 151

Dated: - 23/03/2021

To,

The Manager,  
Maharshi Dayanand Public School,  
2580, Arya Samaj Mandir, Mandir Wali Gali,  
Shadipur Khampur, New Delhi- 110008.

Sub.: - Regarding renewal of Fire Safety Certificate in r/o Maharshi Dayanand Public School, 2580, Arya Samaj Mandir, Mandir Wali Gali, Shadipur Khampur, New Delhi- 110008.

Sir,

Please refer to your e-mail dated 23.01.2021 received through e-mail ID <midschoolshadipur@gmail.com> on the subject cited above. In this connection, it is to inform you that the aforesaid school building have been inspected by the officer concerned of this department on 15.02.2021 in presence of Sh. Joginder Singh, Cashier, to check the functionability of fire safety arrangements.

During the inspection, it was also observed that the school building is comprised of ground plus three upper floors. The upper floors are served by 02 nos. of staircases having width 1.25 & 1.05 mts up to terrace. Fire safety arrangement such as fire extinguishers, hose reel, overhead water tank capacity 5000 lts, etc. found provided. However following shortcomings were observed: -

1. Terrace pump 450 Lpm found provided but not functional.
2. Exit signages found removed.

In view of the above, 'Fire Safety Certificate' cannot be renewed at this stage. You are requested to rectify the above-mentioned fire safety arrangements under intimation to this department.

Yours faithfully

(Sunil Chaudhary)

Dy. Chief Fire Officer  
South Zone

e/c

Copy to: -

The Director of Education,  
Govt. of NCT of Delhi, Old Secretariat,  
New Delhi- 110054.