

CN

GOVERNMENT OF NATIONAL CAPITAL TERRITORY OF DELHI
HEADQUARTERS: DELHI FIRE SERVICE: NEW DELHI- 110001

No.F6/DFS/MS/School/2021/NDZ/ 160

Dated:- 26/03/2021

To,

The Principal,
E.D. M. C. Primary School,
Janta Mazdoor Colony Jafrabad Ext. -II,
Delhi-110053

Subject:- Regarding issue of Fire Safety Certificate.

Sir,

With reference to your letter No. JMC Ext-II/School/118/19/01-21 dated 19/01/2021 on the subject cited above, it is informed that officer concerned of this department inspected the school from fire safety point of view in presence of Mrs. Shakil Fatima, Principal of the school on dated 16//03/2021. The school building comprises of ground plus two upper floors. During the course of inspection following observations were made:-

1. The firefighting system which has been provided in the school building was not functional at the time of inspection.
2. The discharge capacity & head of the fire pump could not ascertained in absence of documents/technician.

In view of the above, the school building cannot be considered for issuance of Fire Safety Certificate at this stage. Therefore, you are requested to rectify the above mentioned fire safety arrangements under intimation to this office and also, provide discharge capacity and head of the fire pump at the earliest for further necessary action.

Yours Faithfully,


24/3/21

(Dr. S. K. Tomar)
Dy. Chief Fire Officer

Copy to:-

The Director of Education, E.D.M.C,
419, Udyog Sadan,
Patparganj Industrial Area,
Delhi -110092