

c-9

GOVERNMENT OF NATIONAL CAPITAL TERRITORY OF DELHI
HEAD QUARTERS: DELHI FIRE SERVICE: CONNAUGHT PLACE
NEW DELHI – 110001

No. F6/DFS/MS/School/WZ/2021/162

Dated: 26/03/2021

To,

The Principal,
N.D.M.C. School,
U.U. Block, Pitampura,
Delhi-110034,

Sub. :- Regarding issuance of Fire Safety Certificate in r/o North Delhi Municipal Corporation School, U.U. Block, Pitampura, Delhi-110034.

Sir,


Please refer to your letter no. Nil dated 16.02.201 on the subject cited above. In this connection it is to inform you that the said building have been inspected by the officer concerned of this department on 04.03.2021 in presence of Ms. Meena Jain (Principal) to check compliance of shortcomings issued by this department vide letter no. F6/DFS/MS/School/2014/474 dated 26.02.2014

During inspection, the following shortcomings have been observed:-

1. 07 Nos. ABC Type Fire Extinguishers are provided but not refilled/updated.
2. 01 No. first Aid Hose reel is provided but Hose Reel Hose & Shut Off Type Nozzel is not provided.
3. A Terrace Pump of 450 lpm capacity is provided but not functional as not connected to power supply.
4. Over Head Water Tank capacity 5000 ltrs. is provided instead of required capacity of 10000 ltrs and not connected to Fire Pump.

In view of the above shortcomings, Fire safety Certificate cannot be grant at this stage. You are advised to rectify the above mentioned shortcomings under intimation to this department for taking further necessary action.

Yours faithfully,


(Dharampal Bhardwaj)
Dy. Chief Fire Officer
(West Zone)

Copy to:-

1. The Director, Directorate of Education Old Secretariat Delhi – 110054