

GOVERNMENT OF NATIONAL CAPITAL TERRITORY OF DELHI
HEADQUARTERS: DELHI FIRE SERVICE: NEW DELHI-110001

No. F.6/DFS/MS/School/SZ/2021/ 156

Dated: 26/03/2021

To

The Principal
Sarvodaya Kanya Vidyalaya No-2,
Mehrauli, New Delhi- 110030.

Sub: Regarding issue of Fire Safety Certificate (FSC) in r/o Sarvodaya Kanya Vidyalaya No- 2,
Mehrauli, New Delhi- 110030.

Sir,

This is in reference to your Gmail Dated 11/03/2021 received of this department, on the subject cited above. In this connection, it is to inform you that the above mentioned premise was visited by the officer concerned of this department on 16.03.2021 in the presence of Smt. Seema Khetarpal (Principal) and observed that the shortcoming intimated vide letter no. F.6/DFS/MS/School2017/SZ/2004 dated 04/08/2017 and observed are as below:-

1. Continuous staircase to terrace not provided, one staircase to be provided to access to the pump house.

In view of above, you are again requested to rectify the shortcoming under intimation to this department for further action.

Yours faithfully,



(Sunil Chawdhary)
Dy. Chief Fire Officer (SZ)
Delhi Fire Service

