

e-22

GOVERNMENT OF NATIONAL CAPITAL TERRITORY OF DELHI
HEAD QUARTERS : DELHI FIRE SERVICE : NEW DELHI – 110001

No.F6/DFS/MS/NDZ/2021/ 168

Dated:- 30 /03/2021

To

Mr. Rakash Kumar
Principal,
East MCD Primary School,
Block no. 3, Kalyanpuri -3II,
Delhi – 110091.

Sub:- Regarding renewal of FSC in r/o East MCD Primary School, Block no. 3, Kalyanpuri, Delhi – 110091.

Sir,

This has reference to your letter no. nil dated 12/02/2021 on the subject cited above. In this regard, it is to inform you that the premises was inspected by the officer concerned of this department on 24/02/2021 in the presence of Mr. Rakash Kumar (Principal) and the following shortcomings were observed :-

1. Fire fighting system such as hose reel, fire pump 450 LPM & fire extinguishers are provided and functional but overhead water tank capacity of 5,000 liter provided against required capacity of 10,000 liter.

Hence, renewal of Fire Safety Certificate can not be considered at this stage.

Yours faithfully


26/3/21

(Dr. S.K. Tomar)
Dy. Chief Fire Officer

Copy to:-

The Joint Director of Education,
(Land & Estate),
Directorate of Education, Lucknow Road, Delhi -54.