GOVERNMENT OF NATIONAL CAPITAL TERRITORY OF DELHI HEADQUARTERS: DELHI FIRE SERVICE: NEW DELHI- 110001

No.F6/DFS/MS/School/2021/NDZ/ 167

Dated: 30 03/2021

To.

The Principal, Sarvodaya Kanya Vidyalaya No. 2, Mansarover Park, Shahdara, Delhi-110032

Subject:- Regarding issue of Fire Safety Certificate.

Sir,

With reference to your letter No. SKVNO2MSP/2021/266 dated 05/03/2021 on the subject cited above, it is informed that officer concerned of this department inspected the school from fire safety point of view in presence of Mr. Veerbhan Tyagi, Estate Manager of the school on dated 16//03/2021. The school building comprises of ground plus three upper floors. During the course of inspection following observations were made:-

- 1. The firefighting system which has been provided in the school building, was not functional at the time of inspection.
- 2. Exit Signs are required to be provided in the school building at all exits.

In view of the above, the school building cannot be considered for issuance of Fire Safety Certificate at this stage. Therefore, you are requested to provide the above mentioned fire safety arrangements under intimation to this office for further course of action.

Yours Faithfully,

(Dr. S. K. Tomar) Dy. Chief Fire Officer

Copy to:-

The Dy. Director of Education, B-Block, Yamuna Vihar, Delhi -110053