

**GOVERNMENT OF NATIONAL CAPITAL TERRITORY OF DELHI
HEAD QUARTERS : DELHI FIRE SERVICE : NEW DELHI – 110001**

No.F6/DFS/MS/School/2021/ 176

Dated: 01/04/2021

To

The Principal,
Bharti Public School,
Sawasthya Vihar, Vikas Marg, Delhi-92.


Sub: Regarding Fire Safety Certificate in r/o Bharti Public School located at Sawasthya Vihar, Vikas Marg, Delhi-92.

Sir,

This has reference to your letter no. BPS/SV/2021/8999 dated 20/02/2021 on the subject cited above. In this regard, it is to inform you that the premises was inspected by the officer concerned of this department on 19/03/2021 in the presence of Dr. Savita Arora (Principal) & Mr. Rajesh (Admin officer) and observed that earlier school was Ground + 03 upper floors but now the school building is comprised of B + Ground + 03 upper floors + Temporary shed at Terrace floor. One audi at ground floor is not having gangway of 1200 mm and no fire safety arrangements are found provided. Therefore this is a case of additional/alteration and needs to route your application through bldg. deptt. of East MCD.

Hence, renewal of Fire Safety Certificate can not be considered at this stage.

Yours faithfully



(Dr. S.K. Tomar)
Dy. Chief Fire Officer
Delhi Fire Service

Copy to:-
The Director (Education),
Govt. of NCT, Old Sectt.
Delhi - 54.

