

C-16

GOVERNMENT OF NATIONAL CAPITAL TERRITORY OF DELHI
HEADQUARTERS: DELHI FIRE SERVICE, NEW DELHI-110001

No.F6/DFS/MS/ School/WZ /2021/ 172

Dated : 30/03/2021

To,

The Principal,
Deep Chand Public School,
Begumpur, Opp. Rohini Sec-22,
Delhi-110086.

Sub:- Issuance of Fire Safety Certificate in r/o Deep Chand Public School, Begumpur, Opp. Rohini Sec-22, Delhi-110086.

Sir,

This is in reference with your letter No. Nil, dated 01.03.2021 received in outdoor diary no. 11544 dated 02.03.2021, on the subject cited above. In this connection this is to inform you that the inspection of the above said premises was carried out by the officer concerned of this department on 18.03.2021 and observed addition of one more floor on existing block of ground + 1 upper floor, making it ground + two upper floors and one more block found constructed in adjacent of existing block. Therefore you are requested to provide the approved building plans duly marked with fire prevention and fire safety provisions for further consideration in this matter.

Yours faithfully


(Atul Garg)
DIRECTOR

Ph; 011-23414000

Encl: As above

The Director of Education, GNCT of Delhi Old Secretariat, Delhi-110054.

o/c
M