

E-9

GOVERNMENT OF NATIONAL CAPITAL TERRITORY OF DELHI
HEADQUARTERS: DELHI FIRE SERVICE: NEW DELHI-110001

NO. F-6/DFS/HQ/2021/171

Dated 30/03/2021

To,

The Principal
Sarvodaya Vidyalaya,
Bhalswa Village, Delhi-110042.

Sub: - Regarding issuance of fire safety certificate in r/o Sarvodaya Vidyalaya, Bhalaswa Village, Delhi-110042. (I.D no. 1309280)


Sir,

Please refer to your letter received through email I.D dated 24.02.2021 on the subject cited above. In this connection this is to inform you that the above mentioned site was visited by the officer concerned of this department on 12.03.2021 to verify the fire safety measures issued vide NBC Part 4 and observed that the school premise is comprised of new blocks- Ground+ 03 upper floors. At the time of inspection Sh. Param Sukh Dev, Vice-Principal was also present at site. During the course of inspection observations/ shortcomings made are as under:-

1. Fire extinguisher provided in the building were checked and found not working at the time of inspection.
2. Hose reel hose provided but not functional and some hose reel nozzle found missing.
3. Terrace level fire fighting pumps capacity of 450 lpm provided but not functional.
4. Exit signage and floor signage not provided at strategic locations in the building.

Keeping in view of above, fire safety certificate cannot be considered at this stage

Yours faithfully


(Dharampal Bhardwaj)
Dy. Chief Fire Officer
Ph:-011-25156707

Copy to:-

1. The Director, Education, Government of N.C.T of Delhi, Old Sectt. Delhi - 110054.