

ETA-2021-010  
e/14

**GOVERNMENT OF NATIONAL CAPITAL TERRITORY OF DELHI  
HEADQUARTERS: DELHI FIRE SERVICE, CONNAUGHT PLACE  
NEW DELHI- 110001**

No. **F6/DFS/MS/School/2021/SZ/ 191**

Dated: **06/04/2021**

To,

The Principal,  
O.K. Model School, at MS-59,  
L-Extn., Mohan Garden, New Delhi-110059.

**Sub:** - Regarding issue of "Fire Safety Certificate" from fire safety point of view in r/o O.K. Model School, MS-59, L-Extn., Mohan Garden, New Delhi-110059.

Sir,

Please refer to letter no. Nil dated 22/03/2021 on the subject cited above. In this connection, it is to inform you that a complete set of approved plan of present occupancy along with the fire safety arrangement provided in the buildings as per NBC Part-IV is required. If the building sanctioned plans are not available then as built plan from a registered architect with section, elevation and dimensions. Also it should be in the scale of 1:100 with duly marked fire fighting system.

Yours faithfully

(Sunil Chawdhary)

**Dy. Chief Fire Officer**  
Delhi Fire Service