

GOVERNMENT OF NATIONAL CAPITAL TERRITORY OF DELHI
HEADQUARTERS: DELHI FIRE SERVICE: NEW DELHI-110001

NO. F-6/DFS/HQ/2020/ 5/ 11

Dated 5/01/2021

To,

The Principal
Sarvodaya Kanya Vidyalaya,
Adarsh Nagar, Delhi 110033.

Sub: - Regarding issuance of fire safety certificate in r/o Sarvodaya Kanya Vidyalaya, Adarsh Nagar, Delhi 110033.


Sir,

Please refer to your letter received through email I.D dated 14.12.2020 on the subject cited above. In this connection this is to inform you that the above mentioned site was visited by the officer concerned of this department on 17.12.2020 to verify the fire safety measures issued vide NBC Part 4 and observed that the school premise is comprised of New blocks- Ground+ 03 upper floors. At the time of inspection Smt. Sunita Rani, Vice-Principal was also present at site. During the course of inspection observations/ shortcomings made are as under:-

1. Fire extinguisher provided in the building were checked and found not working at the time of inspection.
2. Hose reel hose provided in G+03 blocks but not functional.
3. Terrace level fire fighting pump capacity of 450 lpm provided in G+03 blocks but not functional.
4. Overhead tank capacity of 10,000 ltr in G+03 blocks empty.
5. Exit signage not provided at strategic locations in the building.

Keeping in view of above, fire safety certificate cannot be considered at this stage

Yours faithfully


(Dharampal Bhardwaj)
Dy. Chief Fire Officer
Ph:-011-25156707

Copy to:-

1. The Director, Education, Government of N.C.T of Delhi. Old Sectt. Delhi - 110054.