

c/74

GOVERNMENT OF NATIONAL CAPITAL TERRITORY OF DELHI
HEAD QUARTERS: DELHI FIRE SERVICE: NEW DELHI-110001

No.F6/DFS/MS/ *School/192*

Dated: *7/04/2021*

To,

The Principal,
Delhi International School,
Plot No. B-5, Sector-3,
Delhi.

Sub:- Issue of FSC in r/o Delhi International School at Plot No. B-5, Sector-3, Rohini, Delhi-110085

Sir,

This is in reference to online email dated 12/01/2021, received in this department on the subject cited above. The premise was inspected by the team of officers of this department on 22/01/2021, in presence of Sh. Rohit Gupta (Administer) to ascertain the availability and operability of the fire prevention and fire safety measures. Your request for renewal of FSC is considered in rule 35 and rejected under sub rule (4) of Rule 35 of DFS Rules-2010 due to following reason;

1. 6 Meter road all around the building is found reduced by one meter on swimming pool side.

In this regard as stipulated in sub Rule (2) of Rule 37 of DFS Act-2007 & Rules 2010 you may apply with a fresh application for grant of fire safety certificate under sub-rule (2) on form "I", along-with form K for further consideration in this regard. The web links for DFS Act-2007/Rules 2010 & Form "I" & K are as under:

http://www.delhi.gov.in/wps/wcm/connect/doi_fire/FIRE/Home/Fire+Safety+Acts+and+Rules/ht
tp://www.delhi.gov.in/wps/wcm/connect/doi_fire/FIRE/Home/Forms

Yours faithfully

(Atul Gang)
Director

PH: 011-23414000

Copy to:

1. The Director of Education, Old Secretariat, Delhi.