

**GOVERNMENT OF NATIONAL CAPITAL TERRITORY OF DELHI
HEADQUARTERS: DELHI FIRE SERVICE, NEW DELHI-110001**

No: F.6/DFS/MS//2020/Cos/WZ/ 91

Dated: 13/01/2021

To,

Sh. Inderjeet Aneja
Kwality Cosmetics ,
Plot No.142, Pkt-O, Sec-2,
DSI IDC Bawana, Delhi-39

Sub: - Regarding renewal of Fire Safety Certificate in r/o M/s Kwality Cosmetics , located at Plot No.142,Pkt-O, Sec-2, DSI IDC Bawana , Delhi- 110039.

Sir,

This has reference to your Letter received through email ID dated 07.12.2020 on the subject cited above. In this connection, it is to inform you that the above mentioned site was visited by the officer concerned of this department in presence of Sh. Inderjeet Aneja on 17.12.2020 to verify the fire safety arrangements installed in the building. Your request for renewal of FSC is rejected under sub rule(3) of Rule 37, due to following shortcomings:

1. First- Aid Hose Reels provided but not functional.
2. Terrace Pump Provided but not functional.
3. Exit signages found removed at some strategic locations.

Keeping in view of the above Fire Safety Certificate can not be considered at this stage . You are advised to apply again in form 'J' application for renewal of Fire safety certificate (see sub-rule of rule-37) and form 'K' declaration by the owner/occupier (see sub-rule (2) of rule 38) on compliance of the above mentioned request for further consideration. The web link for DFS Act-2007/Rules 2010 & Form 'J' and 'K' are as under :

<http://www.delhi.gov.in/wps/wcm/connect/doi/fire/FIRE/Home/Fire+Safety+Acts+and+Rules/>

[http://delhi.gov.in/wps/wcm/connect/doi fire/FIRE/Home/Forms](http://delhi.gov.in/wps/wcm/connect/doi/fire/FIRE/Home/Forms)

Yours faithfully

(Dharampal Bhardwaj)
Dy. Chief Fire Officer
WEST ZONE

Copy To-

1. M/S Kwality Color Cosmetics, Plot No.142, Pkt-O, Sec-2, DSI IDC, Bawana Delhi-110039.
2. DY. Drug Controller & Licensing Authority , Govt. of NCT of Delhi , F-17, Karkardooma , New Delhi-110032