

GOVERNMENT OF NATIONAL CAPITAL TERRITORY OF DELHI
HEADQUARTERS: DELHI FIRE SERVICE, NEW DELHI-110001

C-23

No. G-6/DFSS(MS)/S/2021/178

Dated: 5/4/21

To,
Authorized Signatory,
Govt. Boys Senior Secondary School No.-3,
Sarojini Nagar, New Delhi-110023.

Subject: Inspection report of Govt. Boys Senior Secondary School No.-3, Sarojini Nagar, New Delhi-110023 (Building No.-17191578) from Fire Safety and means of escape point of view.

Sir,

Please refer to your letter Received through email ID gbsss3sn@gmail.com dated 08/03/2021 on the subject noted above, in this connection, it is to inform you that the said premises was inspected by the officer concerned of this department on 18.03.2021 and presence of Sh. Mahesh Chander (State Manager) and observed that building comprised of Ground & 2 upper floors.

Following shortcomings were found during the inspection:-

1. Hose Reel Hose provided but nonfunctional.
2. Two fire pumps of 450 LPM provided but nonfunctional.

In view of above Fire Safety Certificate cannot be considered at this stage.

You are requested to rectify above mentioned shortcomings under intimation to this department for further necessary action please.

Yours faithfully,



(SUNIL CHAWDHARY)
DY. CHIEF FIRE OFFICER (S.Z.).

Copy to:-

1. The Director of Education, Govt. of NCT of Delhi, Old Secretariat, New Delhi.

Handwritten initials and 'o/c' mark