

C/22

**GOVERNMENT OF NATIONAL CAPITAL TERRITORY OF DELHI
HEADQUARTERS: DELHI FIRE SERVICE: CONNAUGHT PLACE
NEW DELHI- 110001**

No. F.6/DFS/MS/School/2021/SZ/ 195

Dated: 07/04/2021

To

The HOS / Vice Principal,
Govt. Girls Senior Secondary School,
Harkesh Nager, New Delhi 110020

Sub: Reg. renewal of Fire Safety Certificate in r/o Govt. Girls Senior Secondary School, Harkesh Nager, New Delhi (ID 1925341)

Sir,

This is in reference with your Gmail dated 11/03/2021 on the subject cited above. In this regard, school premises have been inspected by officer concerned of this department on dated 25.03.2021 in presence of Sh. Birender Singh (Manager) to verify the status of existing fire prevention and fire safety measures. During the course of inspection, the shortcomings observed are as below;

1. Hose reel found non-functional in ground plus three blocks and not provided in ground plus two upper floor blocks.
2. Terrace pumps found non-functional in ground plus three blocks and not provided in ground plus two upper floor blocks.
3. Overhead tank capacity 10,000 ltrs not provided in ground plus two upper floor blocks.

In view of above shortcomings, renewal of Fire Safety Certificate cannot be considered at this stage. You are requested to rectify the shortcoming under intimation to this department for further action in the matter.

Yours faithfully,

(Sunil Chawdhary)
Dy. Chief Fire Officer (SZ)
Delhi Fire Service

Copy to: -

1. The Director of Education, Govt. of NCT of Delhi, Old Secretariat Delhi 110054