

436

GOVERNMENT OF NATIONAL CAPITAL TERRITORY OF DELHI
HEADQUARTERS: DELHI FIRE SERVICE: NEW DELHI- 110001

No.F6/DFS/MS/School/NDZ/2021 /190

Dated: 05/04/2021

To

The Principal,
Govt. Girls Sr. Sec. School,
Nicholson Road, Mori Gate, Delhi-06

Subject:-Regarding renewal of Fire Safety Certificate in r/o Govt. Girls Sr. Sec. School located at Nicholson Road, Mori Gate, Delhi-06

Madam,


With reference to email letter dated 12.03.2021 on the subject cited above, it is informed that the School building was inspected by Assistant Divisional Officer (SPM) from this department on 22.03.2021 in the presence Mr. P.S. Yadav, Estate Manager and it was observed that the building is comprised of ground + 02 upper floors.

During inspection the following shortcomings were observed.

1. First Aid Hose reels not functional.
2. Fire pump not functional.
3. 2,000 liters overhead tank provided in place of requirement of 10,000 liters.

In view of above shortcomings, the application for issuance for Fire Safety Certificate is rejected. The occupancy of the building/premises in absence of requisite fire safety arrangements shall be at the risk and liability of the school management. The Authority/Statutory Authority may take suitable necessary action as deemed fit.

Yours faithfully,


21/3/21

(Dr. S.K. Tomar)

Dy. Chief Fire Officer

Tel: 011-23412025

o/c A.L.
30/3

Copy to:-

The Directorate of Education,
Govt. of NCT of Delhi, Old Secretariat, Delhi-54