

GOVERNMENT OF NATIONAL CAPITAL TERRITORY OF DELHI
DIRECTORATE OF DELHI FIRE SERVICE: NEW DELHI – 110001

No. F6/DFS/MS/BP/2021/ 80
To

Dated: 05.04.2021

Shri Manish Gupta, Sr. Architect, Project,
Public Works Department, GNCT of Delhi,
8th Floor, MSO Building, I. P. Estate,
New Delhi- 110002.

Sub:-Clearance of building plans from fire safety point of view in r/o proposed construction of Educational building of Govt. Senior Secondary School at SKV Daryapur Kalan, Auchandi Road, Delhi-110039.


Sir,

Please refer to your **Request ID No. PWD/Fire/2021/03/1/149, dated 30.03.2021** of online building plans, on the subject cited above. In this connection, this is to inform you that the referred online building plans in respect of proposed construction of Educational building of Govt. Senior Secondary School at SKV Daryapur Kalan, Auchandi Road, Delhi-110039, have been scrutinized from fire and life safety point of view and observed following shortcomings:-

1. Two numbers of staircases of two meters wide each for assembly occupancy are not proposed as per UBBL-2016.
2. Firefighting arrangements as stipulated in NBC Part-IV/UBBL 2016 are not marked on the building plans.

In view of the above, the building plans are hereby rejected with a request to resubmit plans after rectification of above shortcomings for further consideration in the matter.

Yours faithfully



(Atul Garg)

Director
Delhi Fire Service

2/3/3