

**GOVERNMENT OF NATIONAL CAPITAL TERRITORY OF DELHI
HEADQUARTERS: DELHI FIRE SERVICE: NEW DELHI- 110001**

No. F.6/DFS/MS/School/2021/SZ/ 198

Dated: 07/04/2021

To

The Principal,
Jose Marti Sarvodaya Vidyalaya,
R. K Puram, Sector 12,
New Delhi – 110022

Sub.:- Renewal of Fire Safety Certificate in r/o Jose Marti Sarvodaya Vidyalaya, R. K Puram, Sector 12, New Delhi - 110022


Sir,

This has reference to your letter no nil dated 08/03/2021 on the subject cited above. In this connection, the said school premises have been inspected by concerned nominated of this department on 24/03/2021 in the presence of Sh. Karuna Sree (Principal). During the inspection it was observed that school is comprised of Ground plus two upper floors, Except Auditorium. The shortcomings observed are as below.

1. First Aid Hose Reels are not working.
2. Terrace level pump capacity 450 LPM provided but not working.
3. Overhead tank capacity 10,000 ltrs found empty.
4. Exit signage found removed.

In view of above shortcomings, renewal of Fire Safety Certificate cannot be considered at this stage. You are requested to rectify the shortcoming under intimation to this department for further action in the matter.

Yours faithfully,



**(Sunil Chawdhary)
Dy. Chief Fire Officer (SZ)
Delhi Fire Service**

Copy to: -

1. Directorate of Education, Govt. of NCT of Delhi, Old Secretariat, New Delhi-110054