

C-32

GOVERNMENT OF NATIONAL CAPITAL TERRITORY OF DELHI
HEADQUARTERS: DELHI FIRE SERVICE, NEW DELHI-110001

No. F6/DFS/MS/WZ/2021/

182

Dated: 5/4/21

To,

The Principal,
Junior Model School,
C-13, Suraj Park,
Badli, Delhi-110042.


Sub: Renewal of Fire Safety Certificate in r/o Junior Model School located at C-13, Suraj Park, Badli, Delhi-110042.

Sir,

Kindly reference to online e-mail dated 25.02.2021, received in this department on the subject cited above. In this connection it is to inform you that building plan submitted by you is marked with fire safety arrangements as NBC part-4, as required vide this department letter no F6/DFS/MS/WZ/2020/629 dated 14.09.2020. Therefore, you are advised to comply the letter dated 14.09.2020 completely for further consideration in this matter.

Enclosed:- As above

Yours Faithfully



(Dharampal Bhardwaj)
Dy. Chief Fire Officer

su
11/4/21

129
c/20

GOVERNMENT OF NATIONAL CAPITAL TERRITORY OF DELHI
HEADQUARTERS: DELHI FIRE SERVICE, NEW DELHI-110001

No. F6/DFS/MS/WZ/2020/ 629

Dated: 14/09/2020

To,

The Principal,
Junior Model School,
C-13, Suraj Park,
Badli, Delhi-110042.


Sub: Renewal of Fire Safety Certificate in r/o Junior Model School located at C-13, Suraj Park, Badli, Delhi-110042.

Madam,

This is in reference to letter received in this department through outdoor diary no. 6184 dated 06.07.2020 on the subject cited above. The premise was inspected by the concern nominated authority of this department in presence of Sh. Vijay Sharma M.D on 02.09.2020 to verify the compliance of fire prevention and fire safety measures required as per FSC issued vide this office letter No. 1294 dated 28.08.2017. The renewal of FSC is rejected under sub rule (3) of Rule 37, as there was alteration in building by adding two more floors on existing ground + 1 building.

Hence, you are thereby advice to refer two set of building plans drawn on scale of 1:100, duly marked with fire and life safety provision, through local authority under Section to 2(q) & Rule 34, for further consideration in this matter.

Yours Faithfully



(Atul Garg)
DIRECTOR

Ph; 011-23414000

Encl: As above

The Director of Education, GNCT of Delhi Old Secretariat, Delhi-110054.

ou
14