

e/50

**GOVERNMENT OF NATIONAL CAPITAL TERRITORY OF DELHI
HEADQUARTERS: DELHI FIRE SERVICE: NEW DELHI- 110001**

No. F.6/DFS/MS/School/2021/SZ/ 196

Dated: 07/04/2021

To

The Principal,
Lalit Mahajan SVM School,
Vasant Vihar New Delhi - 110057

Sub.- Renewal of Fire Safety Certificate in r/o Lalit Mahajan SVM School, Vasant Vihar New Delhi - 110057


Sir,

This has reference to your Gmail dated 10/03/2021 on the subject cited above. In this connection, the said school premises have been inspected by concerned nominated of this department on 25/03/2021 in the presence of Sh. Nagendra Kumar Pandey (Principal). During the inspection it was observed that school is comprised of Ground plus three upper floors. The shortcomings observed are as below.

1. First Aid Hose Reels are not working.
2. Terrace level pump capacity 450 LPM provided but not working.
3. Underground tank capacity 50,000 ltrs and Overhead tank capacity 10,000 ltrs found empty.
4. Exit signage found removed.
5. Temporary structure seen at terrace of the building, which needs to be removed.

In view of above shortcomings, renewal of Fire Safety Certificate cannot be considered at this stage. You are requested to rectify the shortcoming under intimation to this department for further action in the matter.

Yours faithfully,



(Sunil Chawdhary)
Dy. Chief Fire Officer (SZ)
Delhi Fire Service

Copy to: -

1. Directorate of Education, Govt. of NCT of Delhi, Old Secretariat, New Delhi-110054

