

**GOVERNMENT OF NATIONAL CAPITAL TERRITORY OF DELHI  
HEADQUARTERS: DELHI FIRE SERVICE: NEW DELHI- 110001**

No. F.6/DFS/MS/School/2021/SZ/ 183

Dated: 5.14.2021

To

The Principal,  
R. J Public School,  
L- Block, Street No – 15,  
Mahipalpur Extension,  
New Delhi 110037

Sub.:- Renewal of Fire Safety Certificate in r/o R. J Public School, L- Block, Street No – 15, Mahipalpur Extension, New Delhi 110037


Sir,

This has reference to your Gmail dated 08/03/2021 on the subject cited above. In this connection, the said school premises have been inspected by concerned nominated of this department on 18/03/2021 in the presence of Sh. R. K Sagwan (Manager). During the inspection it was observed that school is comprised of Basement, Ground plus three upper floors. (Basement Closed & 3<sup>rd</sup> Floor used as residence by the owner). The shortcomings observed are as below.

1. First Aid Hose Reels are not working.
2. Terrace level pump capacity 450 LPM provided not working.
3. Exit signage found removed.

In view of above shortcomings, renewal of Fire Safety Certificate cannot be considered at this stage. You are requested to rectify the shortcoming under intimation to this department for further action in the matter.

Yours faithfully,



(Sunil Chawdhary)  
Dy. Chief Fire Officer (SZ)  
Delhi Fire Service

Copy to: -

1. Directorate of Education, Govt. of NCT of Delhi, Old Secretariat, New Delhi-110054