C-28

GOVERNMENT OF NATIONAL CAPITAL TERRITORY OF DELHI HEADQUARTERS, DELHI FIRE SERVICE, CONNAUGHT PLACE NEW DELHI

No. F6/DFS/MS/SZ/2021/ \ & 6

Dated: 5 / 4 /2021

To.

The Principal, Shiksha Bharti Educational Society, Senior School Sector-8, Dwarka, New Delhi-110075.

Subject: Renewal of Fire Safety Certificate iro Shiksha Bharti Educational Society, Senior School Building Located at Sector-8, Dwarka, New Delhi-110075

Sir,

Please refer to your letter no./ Email Dated 15/03/2021 on the subject mentioned above. In this connection it is to inform you that the premises was inspected by the officer concerned from this department on 18/03/2021 in presence of Mr. Hitesh Bhardwaj (Manager) for fire safety point of view. During the course of inspection the flowing shortcomings are noticed.

- 1. Some Exhaust fans are found removed from basement.
- 2. One Hose reel found removed from basement.
- 3. Public Address System found nonfunctional.
- 4. Communication system from lift Car found removed.

You are requested to comply the abovementioned shortcomings under intimation to this department.

In view of the above shortcomings Fire Safety Certificate cannot be considered at this stage.

Yours faithfully,

Director

Delhi Fire Service

Copy to: 1. Directorate of Education Old Secretariat Delhi – 110054