

GOVERNMENT OF NATIONAL CAPITAL TERRITORY OF DELHI  
HEADQUARTERS: DELHI FIRE SERVICE: CONNAUGHT PLACE  
NEW DELHI-110001

No. F.6/DFS/MS/SZ/2021

68

Dated: .....

11/07/2021

To,

Sh. Virender Singh Negi (Authorize Signatory),  
M/s Munna Lal Ram Dayal, Plot No. A-188,  
Okhla Industrial Area, Phase-I,  
New Delhi-110020

**Subject: -Regarding renewal of fire safety certificate in r/o M/s Munna Lal Ram Dayal,  
Plot No. A-188, Okhla Industrial Area Phase-I, New Delhi-110020**

Sir,

This is in reference to your Email dated 17/12/2020 received in this department on the subject cited above. In this connection, it is to inform you that the officer concerned of this department has carried out the inspection on 30/12/2020 in the presence of Mr. Virender Singh Negi (Authorize Signatory). The following shortcomings have been observed:

1. Fire Check door found removed.
2. Smoke management system basement & upper floors found removed.
3. Smoke & Heat detectors found removed.
4. Automatic sprinkler system found removed basement & upper floors.
5. Exit signage missing at some places.

Yours faithfully



(Sunil Chawdhary)  
Dy. Chief Fire Officer  
Delhi Fire Service

Ok Az

Copy to:

1. The Executive Engineer (Building), SDMC, Jal Vihar, Lajpat Nagar, New Delhi 110024.